



**Trinity Lx200
High Efficiency Gas
Condensing Boiler & Water Heater**

**Suggested
Specification**

Part I - General
Part II - Product
Part III - Installation

Project Name: _____ **Date:** _____

Location: _____

Engineer: _____

Contractor: _____ **Rep:** _____

I. GENERAL

- A. Supply and install ___ modulating and condensing boiler(s)/water heater(s) as specified herein. In terms of this specification, the word “boiler” when used alone designates both heating boiler and water heater unless specifically denoted otherwise.
- B. Each boiler/water heater shall be factory assembled and tested. Each boiler/water heater shall be shipped self-contained and ready for operation except for connection at the installation site of heating piping, fuel, electrical, combustion air, exhaust venting, condensate drainage and relief valve discharge piping.
- C. The boiler/water heater shall be capable of operating on natural gas or LP gas. The boiler/water heater shall be capable of normal operation and full rated input with natural gas supply pressure between 4 inches w.c. [1.0kPa] and 10.5 inches w.c. [2.6kPa], or LP gas supply pressure between 8 inches w.c. [2.0kPa] and 13 inches w.c [3.2kPa]. The boiler/water heater shall be factory set for natural gas, and shall include a factory-supplied kit for conversion to LP gas operation.
- D. The boiler/water heater shall have an AFUE rating of 95.1%, with a minimum input of 25,000 BTU/hr [7.3 kW] and a maximum input of 199,000 BTU/hr [58.3 kW].
- E. The boiler/water heater shall be certified to the ANSI Z21.13 / CSA 4.9 Gas-fired Boiler Standard and ANSI Z21.10.3 / CSA 4.3 Gas Water Heater Standard.
- F. The boiler/water heater shall be certified for installation with zero clearance to combustibles, and shall be certified for closet and alcove installation when vented in accordance with the manufacturer’s instructions.
- G. The boiler/water heater stainless steel heat exchanger shall be designed and constructed in compliance with the ASME Boiler and Pressure Vessel Code Section IV. A permanent nameplate bearing the “H” stamp and National Board registration number shall be attached to the heat exchanger in a readily viewable location.
- H. The heat exchanger shall have a fifteen (15) year limited warranty when installed as a heating boiler. The heat exchanger limited warranty shall be five (5) years when installed as a water heater. All other parts shall have a sixteen (16) month limited warranty covering defects in materials and workmanship. The warranty period is based from the date of manufacture.

II. PRODUCT

- A. Acceptable manufacturers
 - 1. The boiler/water heater shall be Trinity Lx200 manufactured by NY Thermal Inc. (NTI).
- B. Boiler/Water Heater Construction
 - 1. Heat Exchanger and Combustion Chamber
 - (a) The heat exchanger shall be constructed of 316L stainless steel, and mounted in a sealed stainless steel combustion chamber. The heat exchanger and combustion chamber assembly shall be of all-



Trinity Lx200 High Efficiency Gas Condensing Boiler & Water Heater

Suggested Specification

- welded construction. The heat exchanger shall be rated for 145psi [1000kPa] maximum operating pressure.
- (b) The heat exchanger shall be able to accept up to 35% mixture of inhibited propylene glycol HVAC antifreeze, without damage to the heat exchanger or other components.
 - (c) The heat exchanger shall be accessible for inspection and cleaning via a removable burner access cover. The cover shall include a flame observation port.
 - (d) The heat exchanger shall be provided with an automatic air vent.
 - (e) A built-in "U" trap shall be connected to the combustion chamber for collection and removal of condensate. The trap shall be translucent to permit visual inspection and shall be readily removable for cleaning.
2. Gas Train and Combustion System
- (a) The combustion system shall be fully modulating with an 8:1 turndown ratio.
 - (b) The combustion system shall contain:
 - 1) Adjustable air/gas ratio valve with integral regulator
 - 2) Mixing venturi
 - 3) Variable speed blower utilizing pulse width modulation
 - 4) Stainless steel cylindrical premix burner with woven stainless steel mesh covering
 - 5) Dual-electrode spark igniter
 - 6) Independent flame sensing electrode.
3. Venting and Combustion Air
- (a) The boiler shall be designed for venting with 3 inch or 4 inch diameter Schedule 40 PVC, Schedule 40 CPVC, AL29-4C stainless steel or Polypropylene pipe. Maximum exhaust vent length shall be 105 equivalent ft. [32m]. Maximum combustion air inlet length shall be 105 equivalent ft. [32m]. Maximum exhaust vent length with 3 inch pipe with LP gas shall be 50 equivalent ft. [15.2m]. Maximum combustion air inlet length with 3 inch pipe with LP gas shall be 50 equivalent ft. [15.2m].
 - (b) The combustion chamber exhaust outlet shall include a 3/8 inch FNPT access port to permit insertion of a combustion analyzer probe. The access port shall be provided with a 316 stainless steel MNPT threaded plug.
4. Cabinet
- (a) The unit internal structure shall be constructed of 16ga galvanized steel.
 - (b) The cabinet jacket shall be constructed of removable panels fabricated from 20ga steel finished with a durable factory applied coating on both sides. Removal of jacket panels shall not compromise sealing of the combustion chamber.
5. Electrical
- (a) The boiler/water heater shall operate from a 120VAC/1 phase/60Hz power supply with a current draw of 12A.



**Trinity Lx200
High Efficiency Gas
Condensing Boiler & Water Heater**

**Suggested
Specification**

- (b) A line-voltage barrier strip shall be provided for connection of supply power and up to three (3) circulator pumps. The boiler/water heater shall be capable of powering each pump up to a maximum of 1/6HP or 3 Amps @ 120VAC.
- (c) A low-voltage barrier strip shall be provided for connection of:
 - 1) Outdoor temperature sensor
 - 2) System temperature sensor
 - 3) DHW indirect tank aquastat
 - 4) Two (2) heating thermostats
 - 5) External safety limit
 - 6) 4-20mA signal from external control for burner modulation
 - 7) Alarm signal to a building automation system
 - 8) EIA-485 communication for Lead-Lag cascade control.

6. Controls

- (a) The boiler/water control system shall operate on 24VAC provided by an internal 40VA transformer.
- (b) The integrated microprocessor-based controller shall incorporate all operational and safety control functions, including:
 - 1) Burner spark ignition
 - 2) Flame detection and supervision
 - 3) Burner firing rate modulation
 - 4) High temperature limit (UL353 rated)
- (c) The controller shall incorporate a proportional-integral-derivative (PID) algorithm for three (3) separate temperature controls: two (2) for space heating with independent setpoints; one (1) for domestic hot water.
- (d) The controller shall permit field selection of the boiler application as a heating boiler or water heater by means of setting the control response to a high temperature limit excursion. For a heating boiler application set the response to (*select one*) Lockout or Recycle and Delay. For a water heater application set the response to Lockout. The factory set response shall be Lockout.
- (e) The controller shall provide:
 - 1) Operation of up to three (3) pumps: Boiler, Central Heating and Indirect Domestic Hot Water
 - 2) Domestic hot water prioritization with a field-adjustable priority time
 - 3) Field-adjustable outdoor reset to automatically set system water temperature based on outdoor air temperature. An outdoor sensor shall be factory-supplied
 - 4) Manual firing rate control, adjustable between minimum and maximum firing rate
 - 5) Warm weather shutdown to disable heating, with field adjustable setpoint
 - 6) Pump exercise for 10 seconds at 24 hour intervals
 - 7) Freeze protection to operate the boiler and central heat pumps when outlet water temperature falls below 45°F [7.2°C], and fire the burner at minimum modulation when the outlet temperature falls below 38°F [3.3°C]



**Trinity Lx200
High Efficiency Gas
Condensing Boiler & Water Heater**

**Suggested
Specification**

- 8) Field setting of the following:
- Low temperature central heat (CH1) setpoint from 60°F [15.6°C] to 200°F [93.3°C]
 - High temperature central heat (CH2) setpoint from 60°F [15.6°C] to 200°F [93.3°C]
 - Outdoor reset parameters – low temperature central heating
 - Outdoor reset parameters – high temperature central heating
 - Domestic hot water (DHW) setpoint from 60°F [15.6°C] to 200°F [93.3°C]
 - Boiler pump overrun time from 0 to 30 minutes
 - CH and DHW pump overrun time from 0 to 10 seconds
 - CH and DHW pump start delay from 0 to 5 seconds
 - Warm weather shutdown (WWSO) temperature from 50°F [10°C] to 90°F [32.2°C]
 - DHW priority override timer from 0 to 18 hours
 - CH modulation source (inlet, outlet or system water temperature)
 - DHW modulation source (inlet or outlet water temperature)
 - Lead and lag selection method (sequence order or measured runtime)
 - Lead rotation time from 0 to 960 hours
 - Slave order priority method (equalize runtime, use first or use last)
 - Anti short-cycle interval from 0 to 60 minutes
 - Temperature units, °F or °C.
- (f) The control system shall include a built-in colour touchscreen display to permit monitoring of unit operation and field adjustment of control parameters. The control shall support three (3) levels of password-protected access permission: User (no password), Installer, and OEM. The display shall be capable of showing:
- 1) Heat demand source
 - 2) Burner state
 - 3) Demanded firing rate in RPM
 - 4) Actual blower RPM
 - 5) Current setpoint
 - 6) Heat exchanger entering water temperature
 - 7) Heat exchanger exiting water temperature
 - 8) Exhaust gas temperature
 - 9) Outdoor Temperature
- (g) The controller shall be capable of Lead-Lag staging and rotation of up to eight (8) Lx-series boilers with no additional control hardware required, apart from the necessary field-supplied cabling to connect the units via terminals provided on the low-voltage barrier strip. Field configuration of Lead-Lag operation shall be accomplished through the built-in touchscreen display.
- (h) When two (2) or more boilers are connected in a Lead-Lag cascade configuration, the control shall allow for connection of an outdoor temperature sensor on any slave unit, thereby permitting connection of a system temperature sensor on the master unit.



Trinity Lx200 High Efficiency Gas Condensing Boiler & Water Heater

Suggested Specification

C. Trim kit

1. The following shall be factory supplied with each boiler, for field installation:
 - (a) Qty. 1 - Outdoor air temperature sensor, 10k thermistor (used with heating boiler)
 - (b) Qty. 1 - System temperature sensor, 10k thermistor (used with heating boiler)
 - (c) Qty. 1 - Pressure gauge, 0-160psi
 - (d) Qty. 1 - Pressure gauge, 0-30psi (used with heating boiler)
 - (e) Qty. 1 - ¾ inch NPT ASME relief valve, 125psi
 - (f) Qty. 1 - ¾ inch NPT ASME relief valve, 30psi (used with heating boiler)
 - (g) Qty. 1 - LP conversion kit
 - (h) Qty. 2 - 1 x 3 inch Nipple, Brass
 - (i) Qty. 1 - 5 inch length, 3 inch CPVC Schedule 40 pipe
 - (j) Qty. 1 - 1 x 1 x ¾ inch NPT Tee
 - (k) Qty. 2 - 1 inch Vinyl Grommet
 - (l) Qty. 2 - 3 inch diameter anti-bird screen
 - (m) Qty. 1 - 500 ml Fernox F1 Protector (used with heating boiler)
 - (n) Qty. 1 - Wall Mount Bracket

D. Manuals

1. Each boiler shall include the following manuals:
 - (a) Installation and Operating (I&O) manual
 - (b) Controller and display reference manual
 - (c) Heating Boiler application manual
 - (d) Water Heater application manual

III. Installation

A. Boiler/water heater shall be installed and vented in accordance with manufacturers' instructions.

B. Venting

1. The boiler/water heater shall be vented as shown on the plans and specified below:
 - (a) Venting method (*select one*):
 - 1) Sidewall Direct Vent with exterior termination of separate exhaust and combustion air pipes
 - 2) Sidewall Direct Vent with termination by manufacturer specified sidewall termination kit of separate exhaust and combustion air pipes
 - 3) Sidewall Direct Vent with termination by manufacturer specified concentric vent termination kit of separate exhaust and combustion air pipes
 - 4) Vertical Direct Vent with exterior roof-top termination of separate exhaust and combustion air pipes
 - 5) Vertical Direct Vent with termination by manufacturer specified concentric vent termination kit of separate exhaust and combustion air pipes



**Trinity Lx200
High Efficiency Gas
Condensing Boiler & Water Heater**

**Suggested
Specification**

(b) Exhaust venting

- 1) Foam Core pipe is not an approved exhaust vent material and shall not be used.
- 2) Exhaust vent material shall be *(select one)*:
 - (i) 3 inch/4 inch diameter Schedule 40 PVC pipe, Schedule 40 CPVC pipe, AL29-4C stainless steel pipe, or Polypropylene pipe (**Note to specifier - In Canada: all vent pipe materials must meet ULC S636; PVC venting is limited to applications where exiting water temperature from heat exchanger is less than 140°F [60°C]**).
- 3) A 4 x 3 reducer shall be field-supplied if 4 inch pipe is used.
- 4) Exhaust vent length shall not exceed 105 equivalent ft. [32m] of pipe including fittings. (*LP gas only*) Exhaust vent length with 3 inch pipe shall not exceed 50 equivalent ft. [15.2m] of pipe including fittings.

(c) Combustion air inlet

- 1) Combustion air inlet material shall be *(select one)*:
 - (i) 3 inch/4 inch diameter Schedule 40 PVC pipe, Schedule 40 CPVC pipe, or *(to be inserted by specifier using material acceptable to the local AHJ)*.
- 2) A 4 x 3 reducer shall be field-supplied if 4 inch pipe is used.
- 3) Combustion air inlet length shall not exceed 105 equivalent ft. [32m] of pipe including fittings. (*LP gas only*) Combustion air inlet length with 3 inch pipe shall not exceed 50 equivalent ft. [15.2m] of pipe including fittings.